

TOXISCHE GASSEN

Gas	Formule	Nr CAS	lucht=1 ppm	Positie van detector	
Ammonia	NH ₃	07664-41-7	0,59	20	Plafond
Chloor	Cl ₂	07782-50-5	2,49	*	Vloer
Ethyleenoxide	C ₂ H ₄ O	00106-92-3	1,50	1	
Freons	-	-	-	-	Vloer
Kooldioxide	CO ₂	00124-38-9	1,53	5000	Vloer
Koolstofmonoxide	CO	00630-08-0	0,97	25	Luchtweg
Stikstofdioxide	NO ₂	10102-44-0	1,58	3	Luchtweg
Stikstofoxiden	NO	10102-43-9	1,04	25	
Waterstofchloride	HCl	07647-01-0	1,27	5	
Waterstofsulfide	H ₂ S	07783-06-4	1,19	5	Luchtweg
Zwavel dioxide	SO ₂	07446-09-5	2,26	2	Vloer